

# Unit Certificate



FGW TG8 EZE

www.tuv.com  
ID 1900000000

**No.: 968/GI 2127.00/24**

**Grid Integration of Distributed Energy Resources**

**Certificate Holder**

Guangzhou Sanjing Electric Co.,  
Ltd.  
No. 9, Lizhishan Road, Science  
City, Guangzhou High-tech Zone  
Guangdong  
P.R. China

**Subject**

Grid-Connected PV Inverter  
C6-75K-T6-40, C6-100K-T9-40, C6-110K-T12-40, C6-125K-T12-40

**Codes and Standards**

VDE-AR-N 4110:2023  
FGW TG 3:2018 Revision 25  
FGW TG 4:2019 Revision 9  
FGW TG 8:2019 Revision 9

**Scope and result**

The power generating units mentioned above meet the requirements of standards listed above.

The conformity is declared by following documents:

Evaluation Report-No.: 968/GI 2127.01/24, 2024-09-30

Validation Report-No.: 968/GI 2127.00/24, 2024-09-13

Test Report No.: CN23G8N8 001, dated 2024-01-11

The manufacturer has provided proof of certification of the quality management system of his production facility in accordance with ISO 9001 or is subject to production monitoring.

**Specific provisions**

The deviations and conditions for conformity according to the evaluation report must be observed. The corresponding conditions and deviations are listed on page 2 and 3 of the certificate.

Valid until 2029-09-30

The issue of this certificate is based upon an evaluation in accordance with the Certification Program CERT GI3 V5.0:2021-11 in its actual version, whose results are documented in Report No. 968/GI 2127.01/24 dated 2024-07-24. This certificate is specifically valid for the above mentioned system only. It becomes invalid, if any unapproved changes are implemented without prior assessment/approval by the certification body. Authenticity and validity of this certificate can be verified through the above indicated QR-code or at <http://www.fs-products.com>.

**TÜV Rheinland Industrie Service GmbH**

Bereich Automation

Funktionale Sicherheit

Am Grauen Stein, 51105 Köln

Köln, 2024-09-30

Certification Body Safety & Security for Automation & Grid

*A. Kerperin*

Armin Kerperin

[www.fs-products.com](http://www.fs-products.com)  
[www.tuv.com](http://www.tuv.com)



# Unit Certificate

Nr.: 968/GI 2127.01/24

Grid Integration of Distributed Energy Resources

## Technical data of the PGU:

<b>Typ:</b>	C6-75K-T6-40	C6-100K-T9-40	C6-110K-T12-40	C6-125K-T12-40
<b>Rated apparent power:</b>	82.5 kVA	110 kVA	121 kVA	125 kVA
<b>Rated active power:</b>	75 kW	100 kW	110 kW	125 kW
<b>Max. active power (P<sub>600</sub>):</b>	81.90 kW	109.20 kW	120.12 kW	124.09 kW
<b>Rated voltage:</b>	400 V <sub>AC</sub>			
<b>Nominal frequency:</b>	50 Hz / 60 Hz			
<b>Software-Version:</b>	V0.082			

## Validated Simulation Model:

**Reference name:** C6-(75-125)K VDE\_Encrypted.pfd

**MD5 Checksum:** DEB4C697A5291A095CCF13654694706D

**Simulation platform:** DIgSILENT PowerFactory 2023 SP5

# Unit Certificate

**Nr.: 968/GI 2127.01/24**

**Grid Integration of Distributed Energy Resources**

## **The following deviations and restrictions apply:**

☐ None

### ☒ **The following:**

- A voltage deadband cannot be set for Q(U)-control. If required, this has to be implemented on PGS level (e.g. via PGS controller).
- An external interface for specifying the reference voltage  $U/U_c$  is not implemented (Q(U)-control). If required, this has to be implemented on PGS level (e.g. via PGS controller).
- The PGU control only supports five reference points for Q(P) control. If more reference points are needed, the Q(P) control must be implemented on PGS level (e.g. by PGS controller).
- The PGU contains one single interface for active power setpoint. Separate interfaces for setpoint specifications including compliant prioritization of setpoints regarding active power (e.g. grid operator, direct marketer) must be implemented at PGS level (e.g. by PGS-controller) and be evaluated as part of system certification.
- The certified product does not provide a test terminal. A connecting terminal plate has to be installed separately, if necessary. Alternatively, this requirement can be fulfilled on PGS level through an intermediate decoupling protection device with valid component certificate according VDE-AR-N 4110 and separate circuit breaker.
- As the unit does not contain a display, this has to be considered on project level. With regard to the requirements of the corresponding grid provider, an appropriate device to check the protection settings has to be provided on demand or should be stored on site.
- The validated simulation model of the PGUs specified shall be used in the certified version (see information above for details on file name and check sum (MD5)).

# Unit Certificate

**Nr.: 968/GI 2127.01/24**

## Grid Integration of Distributed Energy Resources

### Schematic overview of the PGU:

